



# Certificate of Compliance

**Certificate:** 2610087 (LR 44770-4)

**Master Contract:** 165491

**Project:** 2610087

**Date Issued:** April 8, 2013

**Issued to:** Elektron Technology UK Ltd

**Broers Building  
JJ Thomson Avenue  
Cambridge, CB3 0FA  
United Kingdom  
Attention: Vivian Benest**

*The products listed below are eligible to bear the CSA Mark shown*



*John Lam*

**Issued by:** John Lam

## **PRODUCTS**

### **CLASS 6225 01 - FUSEHOLDER ASSEMBLIES**

Series 0322, 6.3A, 250V, extractor type for 5 mm dia by 20 mm fuses, for panel mounting, finger release.

Series 0333, 6.3A, 250V, extractor type for 5 mm dia by 20 mm fuses, for panel mounting, tool release.

Series 0340, 6.3A, 250V, extractor type for 5 mm dia by 20 mm fuses or 3/16 in dia by 5/8 in fuses, for panel mounting.

Series 0345, 6.3A, 250V, extractor type for 5 mm dia by 20 mm or 3/16 in by 5/8 in fuses and 16A, 250V for 1/4 in dia by 1-1/4 in fuse, for panel mounting.

Series 0347, 6.3A, 250V, extractor type for 5 mm dia by 20 mm or 3/16 in by 5/8 in fuses and 16A, 250V for 1/4 in dia by 1-1/4 in fuse, for panel mounting.

Series 0341, 6.3A, 250V, extractor type for 5 mm dia by 20 mm or 3/16 in by 5/8 in fuses, for panel mounting.

Note: These fuseholders are Certified for use only as components in other equipment where the acceptability has been determined by the CSA International

## **APPLICABLE REQUIREMENTS**



**Certificate:** 2610087 (LR 44770-4)

**Master Contract:** 165491

**Project:** 2610087

**Date Issued:** April 8, 2013

---

CSA Std C22.2 No. 39-M1987 - Fuseholder Assemblies